

**Mount Washington Road Bridge Replacement & Related Work**  
Mount Washington Road  
Egremont, Massachusetts

**ADDENDUM #2**  
May 24, 2016

The Original Bid Documents, including the Contract Documents, Specifications and Plans, are hereby amended as noted in this Addendum No. 2, dated May 24, 2016.

Contractor shall acknowledge receipt of this Addendum by inserting its number and date in the space provided in the Bid Documents.

1. The horizontal and vertical limit of the existing abutments is unknown at this time. If required for installation of the proposed 3-sided box culvert and strip footings, the contractor shall provide an existing abutment and soil support system, with water control, between the remaining portions of existing abutment and the new precast structure. For the comparison of bids an estimated quantity for Contingency Item C-1, Existing Abutment Support is 40 linear feet. Please provide the required information in the attached Bid Form – Contingency Items. Prior to construction, the contractor shall provide stamped drawings and calculations for the support system including, but not limited to, shoring details and/or underpinning with concrete, at no additional compensation.
2. The date and time of the bid opening remains unchanged.
3. Please acknowledge receipt of this Addendum #2 on the Bid Form.

**BID FORM - CONTINGENCY**  
**MOUNT WASHINGTON ROAD BRIDGE REPLACEMENT & RELATED WORK**

ITEM NO.	QUANTITY	ITEM WITH UNIT BID PRICE WRITTEN IN WORDS	UNIT PRICE DOLLARS & CENTS	AMOUNT DOLLARS & CENTS
C-1	40 LF	Existing Abutment Support at _____ per Linear Foot		

**TOTAL OF BASE BID PLUS CONTINGENCY IN WORDS:**

\_\_\_\_\_

**TOTAL BASE BID PLUS CONTINGENCY = \$** \_\_\_\_\_

Town of Egremont  
 Mount Washington Road Bridge Replacement & Related Work

Contractor: \_\_\_\_\_  
 (Please Print)

Date: \_\_\_\_\_